






IEC 62080,
EN 54-3, 33404-3







310.444.001.0410 © D



WERMA Signaltechnik GmbH + Co. KG
D-78604 Rietheim-Weilheim
Telefon +49 (0)7424 / 9557-0
Telefax +49 (0)7424 / 9557-44
info@werma.com
www.werma.com



- (D) Anschluss **ausschließlich** durch ausgebildete Elektro-Fachkräfte.
- (GB) Electrical connection is to be made by trained electrical specialists **only**.
- (F) Le branchement doit **uniquement** être effectué par des professionnels.
- (I) Il collegamento deve essere eseguito **solo** da elettricisti specializzati.
- (E) La conexión **sólo** debe ser realizada por electricistas debidamente formados.
- (PT) A ligação deve ser feita **exclusivamente** por profissional eléctrico especializado.
- (NL) De aansluiting mag **enkel** gebeuren door erkende vakmensen.
- (CZ) Připojení smí **provádět** pouze kvalifikovaný personál.
- (PL) Podłączenie **wyłącznie** przez specjalistów-elektryków.
- (FI) Liittäminen kuuluu **ainoastaan** koulutettujen sähköalan ammattilaisten tehtäviin.
- (RUS) Подключение проводится только специалистом-электриком.
- (TR) Bağlantı **sadece** eğitimli elektrik teknisyenleri tarafından yapılmalıdır.
- (CN) 布线需由专业电工执行



444 x10 xx

- (D) Bei Epilepsie ungeeignet!
- (GB) Unsuitable for epilepsy sufferers
- (F) Ne convient pas aux personnes souffrant d'épilepsie
- (I) Inadatto per epilettici
- (E) Inadecuado para epilépticos
- (NL) Niet geschikt voor epileptici.
- (PT) Não aconselhaven a pessoas que sofrem de Epilepsia
- (CZ) Nevhodné pro epileptiky
- (PL) Nie stosować przy zchorzeniu padaczki
- (FI) Ei sovellu epileptikoille
- (RUS) Не подходит для страдающих эпилепсией
- (TR) Epilepsi hastalığı olanların kullanmaması önerilir
- (CN) 不适用于癫痫病患者



I (U)

	U		
144 000 75	24 V AC / DC	200 mA	-
144 000 66	48 V AC 50/60 Hz	140 mA	-
144 000 67	115 V AC 50/60 Hz	55 mA	-
144 000 68	230 V AC 50/60 Hz	30 mA	-
444 x00 75	24 V AC / DC	200 mA	60 mA
444 x00 66	48 V AC 50/60 Hz	140 mA	40 mA
444 x00 67	115 V AC 50/60 Hz	55 mA	30 mA
444 x00 68	230 V AC 50/60 Hz	30 mA	30 mA
444 x10 75	24 V AC / DC	200 mA	80 mA
444 x10 66	48 V AC 50/60 Hz	140 mA	45 mA
444 x10 67	115 V AC 50/60 Hz	55 mA	30 mA
444 x10 68	230 V AC 50/60 Hz	30 mA	30 mA



(vgl. Abb. 4,8 / see Fig. 4,8 / ref. III 4,8)





Ton Tone Ton 1	Code	Tonart Tone type Tonalité	Fre- quenz Fre- quencies Fré- quence	Beschreibung Description Description	Einsatz Use Utilisation	Ton Tone Ton 2	Ton Tone Ton 3
1	00000	Dauerton. continuous, contin	200		BS 5839-1: 2002, VDS	440Hz cont.	554Hz cont.
2	00001	ansteigend, rising, montant	800 & 970	7Hz		14	800Hz cont.

3	00010	ansteigend, rising, montant	800 & 970	1Hz			14	800Hz cont.
4	00011	Dauerton, continuous, contin	2850				14	9
5	00100	ansteigend, rising, montant	2400 to 2850	7Hz	VDS		4	2400Hz z cont.
6	00101	ansteigend, rising, montant	2400 to 2850	1Hz			4	2400Hz z cont.
7	00110	ansteigend, rising, montant	500 to 1200	3s, then 0.5s OFF (then repeat)			14	8
8	00111	abfallend, falling, incliné	1200 to 500	1Hz	VDS		14	7
9	01000	alternie- rend, alter- nating, alternant	2400 & 2850	2Hz			4	2400Hz z cont.
10	01001	pulsierend, pulse, pulsant	970	0.5Hz (1s On/1s Off)	BS 5839- Teil 1 1988		14	800Hz cont.
11	01010	alternie- rend, alter- nating, alternant	800 & 970	1Hz	BS 5839- Teil 1 1988		14	800Hz cont.
12	01011	pulsierend, pulse, pulsant	2850	0.5Hz			4	22
13	01100	pulsierend, pulse, pulsant	970	0.25s On/1s Off			14	800Hz cont.
14	01101	Dauerton, Continuous, Continu	970		BS 5839-1: 2002 PFEER - Toxic gas		10	8
15	01110	alternie- rend, alter- nating, alternant	554 & 440		France NFS		14	800Hz cont.
16	01111	pulsierend, pulse, pulsant	660	150ms On/ 150ms Off	Swedish		16	14
17	10000	pulsierend, pulse, pulsant	660	1.8s On/ 1.8s Off	Swedish		17	14
18	10001	pulsierend, pulse, pulsant	660	6.5s On/ 13s Off	Swedish		18	14
19	10010	Dauerton, continuous, contin	660		Swedish		19	31
20	10011	alternie- rend, alter- nating, alternant	554 & 440	0.5Hz			20	19
21	10100	pulsierend, pulse, pulsant	660	1Hz	Swedish		21	4
22	10101	pulsierend, pulse, pulsant	2850	150ms On/ 100ms Off	GB		14	4
23	10110	ansteigend, rising, montant	800 to 970	50Hz (niedrig, low, faible)	BS 5839- Teil 1 1988		14	800Hz cont.
24	10111	ansteigend, rising, montant	2400 to 2850	50Hz (hoch, high, fréquence éle- vée)			4	2400Hz z cont.
25	11000	pulsierend, pulse, pulsant	970	3x500ms ON/500ms OFF 1.5s Pause, dann Wiederholung, 3x500ms ON/ 500ms OFF 1.5s silence then repeat 3x500ms ON/ 500ms OFF 1.5s de pause et ensuite répétition (niedrig, low, faible)	ISO 8201/ US Tempo- ral		26	14



26	11001	pulsierend, pulsant	2850	3x500ms ON/500ms OFF 1.5s Pause, dann Wiederholung, 3x500ms ON/500ms OFF 1.5s silence then repeat 3x500ms ON/500ms OFF 1.5s de pause et ensuite répétition (hoch, high, fréquence élevée)	ISO 8201/ US Temporal	25	4
27	11010	Dauer-ton, continuu	4000			27	6
28	11011	ansteigend, rising, montant	2000 to 2850	7Hz		2000 Hz cont.	4
29	11100	alternierend, alternating, alternant	988 & 645	2Hz		988Hz cont.	645Hz cont.
30	11101	alternierend, alternating, alternant	510 & 610	2Hz		510Hz cont.	610Hz cont.
31	11110	alternierend, alternating, alternant	800 & 970	2Hz	5839-1: 2002	800 cont.	14
32	11111	alternierend, alternating, alternant	800 & 1200	1Hz		800 cont.	1200Hz cont.








1
1a - 144, 444
1b - 144, 444



4
4a - 144 000 75, 144 000 66, 144 000 67,
144 000 68
4b - 444 xx0 75, 444 xx0 66, 444 xx0 67,
444 xx0 68



5
5a - 144, 444
5b - 144, 444 + 975 444 01



310.444.001.0410